

|                             |       |            |
|-----------------------------|-------|------------|
| INSULATION TEST CERTIFICATE | Nr.:  | 107343     |
|                             | Date: | 09/07/2026 |

Pag. 1 de 1.

|                          |                                                                                                                                                                                                                                                                                                                          |
|--------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 1. GENERAL TEST DATA     |                                                                                                                                                                                                                                                                                                                          |
| Requester:               | Tramontina Garibaldi S.A. Ind. Met.                                                                                                                                                                                                                                                                                      |
| Test date:               | 09/07/2026                                                                                                                                                                                                                                                                                                               |
| Place:                   | Tramontina Garibaldi S.A. Test Laboratory, located at Tramontina Street, 600 – Garibaldi – RS                                                                                                                                                                                                                            |
| Environmental Condition: | Temperature from 18 °C to 28 °C and 45% to 75% relative humidity                                                                                                                                                                                                                                                         |
| Test method:             | Before the test, the sample is conditioned as described in IEC 60900:2018, sections 5.5.2.2 or 5.5.2.3. After the conditioning period, the sample is submitted to voltage of 10 kV r.m.s (60 Hz) for 3 minutes, in accordance with item 5.5.3 – Dielectric Test of Insulated Hand Tools, of the aforementioned standard. |

|                               |                                                                                                |
|-------------------------------|------------------------------------------------------------------------------------------------|
| 2. TESTED ITEM IDENTIFICATION |                                                                                                |
| Manufacturer:                 | Tramontina Garibaldi S.A. Ind. Met.                                                            |
| Description of tested item:   | 1/2" IEC 60900 6 Point Socket 24mm                                                             |
| Reference:                    | 44335/024                                                                                      |
| Manufacturing order number:   | 1217926                                                                                        |
| Sample:                       | The tested samples come from the industrial process of the aforementioned manufacturing order. |

|                            |                                                                                                                                    |
|----------------------------|------------------------------------------------------------------------------------------------------------------------------------|
| 3. STANDARD IDENTIFICATION |                                                                                                                                    |
| Equipment:                 | High Voltage Source                                                                                                                |
| Identification Number:     | 100/013                                                                                                                            |
| Traceability:              | Calibrated by LABELO Laboratory, recognized by Cgcre/Inmetro CAL 0024, Calibration Certificate No. E0012/2026, according to PL015. |

|                                                         |          |
|---------------------------------------------------------|----------|
| 4. TEST RESULT IN ACCORDANCE TO IEC 60900:2018 STANDARD |          |
| Batch representative sample                             | RESULT   |
| 44335/024                                               | Approved |

**NOTES:**

- a) This tool underwent insulation testing, and even after long storage periods, it is suitable for use.  
After the first application, annual recertification is necessary.
- b) The results shown herein are related exclusively to the tested tool, within the specified conditions.  
They cannot be extended to any lot, even for similar products.
- c) This document may only be reproduced in full. Partial reproduction requires written approval from the laboratory.



Eng. José Carlos Rizzolli  
Authorized Signer