

INSULATION TEST CERTIFICATE

Nr.:

108167

Date:

05/08/2026

Pag. 1 de 1.

1. GENERAL TEST DATA

Requester:	Tramontina Garibaldi S.A. Ind. Met.
Test date:	05/08/2026
Place:	Tramontina Garibaldi S.A. Test Laboratory, located at Tramontina Street, 600 – Garibaldi – RS
Environmental Condition:	Temperature from 18 °C to 28 °C and 45% to 75% relative humidity
Test method:	Before the test, the sample is conditioned as described in IEC 60900:2018, sections 5.5.2.2 or 5.5.2.3. After the conditioning period, the sample is submitted to voltage of 10 kV r.m.s (60 Hz) for 3 minutes, in accordance with item 5.5.3 – Dielectric Test of Insulated Hand Tools, of the aforementioned standard.

2. TESTED ITEM IDENTIFICATION

Manufacturer:	Tramontina Garibaldi S.A. Ind. Met.
Description of tested item:	8 mm IEC 60900 Insulated Hex Key
Reference:	44318/008
Manufacturing order number:	1225535
Sample:	The tested samples come from the industrial process of the aforementioned manufacturing order.

3. STANDARD IDENTIFICATION

Equipment:	High Voltage Source
Identification Number:	100/013
Traceability:	Calibrated by LABELO Laboratory, recognized by Cgcre/Inmetro CAL 0024, Calibration Certificate No. E0012/2026, according to PL015.

4. TEST RESULT IN ACCORDANCE TO IEC 60900:2018 STANDARD

Batch representative sample	RESULT
44318/008	Approved

NOTES:

- a) This tool underwent insulation testing, and even after long storage periods, it is suitable for use.
After the first application, annual recertification is necessary.
- b) The results shown herein are related exclusively to the tested tool, within the specified conditions.
They cannot be extended to any lot, even for similar products.
- c) This document may only be reproduced in full. Partial reproduction requires written approval from the laboratory.



Eng. José Carlos Rizzolli
Authorized Signer